

PERMISIONARIO: Centro Nacional de Control del Gas Natural
 PUNTO DE MEDICION: Torreón
 ZONA DE MEDICION: RESTO DEL PAIS

FECHA: (dd/mm/aa)	Metano (% vol)	Bióxido de Carbono (% vol)	Nitrogeno (% vol)	Total Inertes (% vol)	Etano (% vol)	Temp. de Rocio (K)	Humedad (mg/m3)	Poder Calorífico (MJ / m3)	Indice Woobe (MJ / m3)	Acido Sulhídrico (mg / m3)	Azufre total* (mg / m3)	Oxigeno* (% vol)
01/12/16 09:00:00	96.6518	0.6640	0.3087	0.9727	2.1701	257.5383	21.9132	38.1784	50.3188	0.0353		
02/12/16 09:00:00	96.7023	0.6551	0.3294	0.9845	2.0769	258.2114	23.5826	38.1680	50.3087	0.0391		
03/12/16 09:00:00	95.5324	0.7523	0.2604	1.0127	3.1884	259.0047	20.5659	38.4956	50.4599	0.0457		
04/12/16 09:00:00	94.6048	1.0064	0.2866	1.2931	3.7957	261.7169	18.2062	38.5935	50.3270	0.0433		
05/12/16 09:00:00	94.7063	0.9924	0.2900	1.2824	3.7382	258.6241	21.3465	38.5557	50.3141	0.0610		
06/12/16 09:00:00	94.0834	1.0161	0.2608	1.2769	4.3578	257.9942	21.5689	38.7378	50.4154	0.1299		
07/12/16 09:00:00	94.1370	1.0158	0.2571	1.2728	4.3047	258.5432	19.9156	38.7266	50.4106	0.1330		
08/12/16 09:00:00	94.6575	0.9066	0.2760	1.1826	3.8740	259.7278	16.2462	38.6396	50.4267	0.0598		
09/12/16 09:00:00	95.8897	0.7632	0.2008	0.9639	2.8437	262.6592	15.9957	38.4456	50.4497	0.0746		
10/12/16 09:00:00	96.6948	0.7088	0.1799	0.8886	2.1799	258.5412	16.0819	38.2350	50.3777	0.0557		
11/12/16 09:00:00	96.6495	0.6907	0.1884	0.8791	2.2289	258.5812	17.1198	38.2572	50.3991	0.0249		
12/12/16 09:00:00	96.9142	0.6697	0.1815	0.8512	2.0098	257.4602	16.6217	38.1917	50.3798	0.0806		
13/12/16 09:00:00	96.8699	0.6535	0.1964	0.8500	2.0548	258.0187	17.8674	38.2056	50.3923	0.0366		
14/12/16 09:00:00	96.8771	0.6737	0.1769	0.8507	2.0455	259.0416	18.2956	38.2049	50.3867	0.0329		
15/12/16 09:00:00	96.8245	0.6177	0.1779	0.7957	2.2116	255.2604	17.1890	38.2307	50.4409	0.0397		
16/12/16 09:00:00	96.8228	0.6255	0.1788	0.8043	2.1738	255.4530	15.6733	38.2364	50.4381	0.0445		
17/12/16 09:00:00	96.8326	0.6390	0.1984	0.8374	2.0731	261.4859	14.7866	38.2404	50.4213	0.0514		
18/12/16 09:00:00	96.8239	0.6931	0.1706	0.8638	2.0783	260.1847	13.1020	38.2151	50.3816	0.0320		
19/12/16 09:00:00	96.8775	0.6247	0.2184	0.8431	2.0466	254.8843	13.0254	38.2076	50.4036	0.0345		
20/12/16 09:00:00	96.6738	0.7015	0.1785	0.8800	2.1945	256.5563	15.7656	38.2489	50.3914	0.0521		
21/12/16 09:00:00	96.5325	0.7134	0.1719	0.8853	2.3186	255.9420	23.9834	38.2894	50.4091	0.0778		
22/12/16 09:00:00	96.5189	0.7270	0.1872	0.9141	2.2624	261.7755	25.0898	38.2968	50.3965	0.1014		
23/12/16 09:00:00	96.4331	0.7324	0.1991	0.9315	2.3275	262.0441	24.5931	38.3125	50.3961	0.1335		
24/12/16 09:00:00	96.5105	0.7338	0.2114	0.9452	2.2500	262.0416	23.4165	38.2758	50.3684	0.1889		
25/12/16 09:00:00	96.7922	0.7082	0.1830	0.8911	2.1057	257.3540	23.1313	38.1934	50.3531	0.1488		
26/12/16 09:00:00	96.7146	0.6777	0.2336	0.9113	2.1486	257.1201	22.4065	38.2068	50.3587	0.0925		
27/12/16 09:00:00	96.9608	0.6509	0.2112	0.8621	1.9594	257.3165	20.3448	38.1677	50.3659	0.1066		
28/12/16 09:00:00	96.8105	0.6946	0.2280	0.9226	1.9942	258.2899	21.4277	38.1912	50.3402	0.1720		
29/12/16 09:00:00	96.6597	0.6822	0.2440	0.9262	2.1203	259.0324	21.8457	38.2397	50.3691	0.1589		
30/12/16 09:00:00	96.6597	0.6822	0.2440	0.9262	2.1203	259.0324	19.9256	38.2397	50.3691	0.2740		
31/12/16 09:00:00	96.6597	0.6822	0.2440	0.9262	2.1203	259.0324	22.7559	38.2397	50.3691	0.1218		

*/ Los valores trimestrales se deberán reportar en los meses de enero, abril, julio y octubre de cada año, respecto del trimestre inmediato anterior.

Mínimo	94.0834	0.6177	0.1706	0.7957	1.9594	254.8843	13.0254	38.1677	50.3087	0.0249		
Promedios	96.2928	0.7340	0.2217	0.9557	2.4959	258.6603	19.4771	38.3118	50.3851	0.0865		
Maximo	96.9608	1.0161	0.3294	1.2931	4.3578	262.6592	25.0898	38.7378	50.4599	0.2740		
D. Standard	0.8813	0.1195	0.0444	0.1459	0.7257	2.0638	3.4628	0.1689	0.0390	0.0584		

Observaciones: